

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/School/2018/SZ/ 2444

Dated: 31/10/18

FIRE SAFETY CERTIFICATE

Certified that the Holy Child Auxilium School, located at Poorvi Marg, Vasant Vihar, New Delhi-110057 comprised of ground plus two upper floors was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2015/SZ/1839 dated 13/10/2015. The premises was re-inspected by officer concerned of this department on 15/10/2018 in presence of Mrs. Anita (Incharge) and observed that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational Building" Group-B, with effect from the date of issue of this certificate for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/10/18 at New Delhi by

Vipin Kental

(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Principal, Holy Child Auxilium School, Poorvi Marg, Vasant Vihar, New Delhi-110057.
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

For the purpose of School Website

Attested

[Signature]

Principal
Holy Child Auxilium School
Poorvi Marg, Vasani Vihar
New Delhi-110057